

まつもと市民芸術館の室内化学物質濃度測定調査結果

測定項目		アセトアルデヒド		ホルムアルデヒド	トルエン	キシレン	パラジクロロベンゼン	エチルベンゼン	スチレン	テトラデカン	フタル酸ジ-n-ブチル	フタル酸ジ-2-エチルヘキシル	クロルピリホス	ダイアノジン	フェノブカルブ
測定日	指針値	48 µg/m ³		100 µg/m ³	260 µg/m ³	870 µg/m ³	240 µg/m ³	3,800 µg/m ³	220 µg/m ³	330 µg/m ³	220 µg/m ³	120 µg/m ³	1 µg/m ³ (小児は0.1)	0.29 µg/m ³	33 µg/m ³
7/20	1F スタッフルーム	88	N.D.	15	150	45	N.D.	40	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
	1F 楽屋1	130	10	18	58	27	N.D.	20未満	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
	1F アトリエ1	98	10未満	22	24	20未満	N.D.	20未満	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
	1F 楽屋11	100	N.D.	10未満	20未満	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
	1F 大ホール土間席	14		30	67	27	N.D.	23	N.D.	N.D.	10未満	N.D.	N.D.	N.D.	N.D.
8/1	M2 廊下1	12		10未満	25	20未満	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
	M2 廊下2	15		11	48	64	N.D.	30	20未満	20未満	N.D.	N.D.	N.D.	N.D.	N.D.
	M2 楽屋1	10未満		10未満	20未満	20未満	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
	M2 楽屋3	10未満		10未満	20未満	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
	M2 会議室1	10未満		10未満	20未満	20未満	N.D.	20未満	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
	M2 防災課	10未満		10未満	20未満	20未満	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
	2F 小ホール客席	21		29	57	20未満	N.D.	20未満	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
	2F ホワイエ	18		18	49	70	N.D.	33	20未満	20未満	N.D.	N.D.	N.D.	N.D.	N.D.
8/2	1F 事務室	12		20	36	81	N.D.	37	N.D.	20未満	N.D.	N.D.	N.D.	N.D.	N.D.
	1F 館長室	18		20	47	210	N.D.	60	20未満	20未満	N.D.	N.D.	N.D.	N.D.	N.D.
	1F 発声室	10未満		10未満	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
	3F スタジオ2	92	10未満	47	91	260	N.D.	110	N.D.	20未満	N.D.	N.D.	N.D.	N.D.	N.D.
	3F スタジオ3	59	10未満	33	60	40	N.D.	30	N.D.	20未満	N.D.	N.D.	N.D.	N.D.	N.D.
	2B 親子室	10未満		16	20	23	N.D.	20未満	N.D.	20未満	N.D.	N.D.	N.D.	N.D.	N.D.
	1B バルコニー客席	17		22	55	22	N.D.	20未満	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.
	4B バルコニー客席	15		26	60	24	N.D.	20未満	N.D.	N.D.	10未満	N.D.	N.D.	N.D.	N.D.
定量下限値		10		10	20	20	20	20	20	20	10	10	0.05	0.05	3
検出下限値		3		3	6	6	6	6	6	6	3	3	0.02	0.02	1

* 88 指針値を越えている値

* 定量下限値未満検出下限値以上は 未満で表示

* 検出下限値未満はN.D.で表示

* アセトアルデヒドの右欄は再測定値(測定8月18日)